## Fire Equipment Signs









6 Kg CO. fire extinguisher PV 6087 JJ



9 litre powder fire extinguisher PV 6088 JJ



45 litre wheeled powder fire . extinguisher PV 6089 JJ



5 litre powder fire extinguisher PV 6090 JJ



9 Litre Foam Fire Extinguisher PV 6091 JJ



Fire extinguisher spare charge PV 6715 JJ



Safety plan PV 4132 JJ



PV, PR 6430 KG



PV, PR 6431 KG



PV, PR 6432 KG



PV, PR 6433 KG



PV, PR 6414 KG





PV, PR 5876 KJ



PR 6500 Z Individual sign size KK



PR 6501 Z Individual sign size JJ



PR 6502 Z Individual sign size KK



PR 6503 Z Individual sign size JJ



PR 6507 Z A Individual sign size JJ



WV 2702 1G



PR 6504 Z Individual sign size KK



PR 6505 Z A Individual sign size JJ



PR 6506 Z Individual sign size KK



## Regulations

SOLAS Chapter II-2 Consolidated 2001 edition regulation 28.10 refers to the location markings for fire equipment locations and requires that they must be illuminated by emergency lighting or of photoluminescent material.

## Installation

Each item of fire fighting equipment should be marked with the appropriate symbol. Where various types of equipment are stored at one location, 'Fire Point' signs may be used. When equipment in an alley or corridor is stowed in a recess or locker, then a panoramic sign, mounted well above head height should be used to enable the equipment to be identified from a distance (see page 1 for details of recommended viewing distances).

Any space protected by a CO<sub>2</sub> blanketing system must have all entrance doors and hatches marked by the appropriate sign. See signs 5876 KJ & 7545 KJ on the right of this page.

All elevator entrances should be marked with sign 6300 JJ shown on the opposite page.

Fire extinguishers may be further identified as to their use with signs 6430 KG to 6433 KG which comply with BS Regulation EN 3.